



# Catálogo

## Acumulador de Succión



[www.rgcrefrigeration.com](http://www.rgcrefrigeration.com)



¡Síguenos en nuestras RRSS @rgcrefrigeracion!

# ACUMULADOR DE SUCCIÓN

Acumulador de Succión RGC . Proteja su compresor de posibles daños ocasionados por la entrada repentina de refrigerante líquido o a través de la línea de succión hacia el compresor.



El Acumulador de Línea de Succión de la serie FDQ ha sido meticulosamente diseñado para salvaguardar el compresor de posibles inundaciones repentinas de refrigerante en fase líquida.

Con el Acumulador de Succión RGC, usted puede tener la tranquilidad de garantizar el óptimo funcionamiento de su sistema de Refrigeración.


## Especificaciones Técnicas

Carcasa	
Hermética	
Refrigerantes Compatibles	
HCFC-HFC-HFO-HC	
Presión Máxima de trabajo	
30 bar/ 500 psig	
Rango de Temperatura	
-40 °C a 70°C	


## Aplicaciones

Refrigeración Comercial	
Refrigeración Industrial	

Modelo	Diámetro de conexión	Dimensiones					Capacidad Nominal con R404A		Volúmen	Modelo
		ΦD	A	L	H	M	kW			
		pulg	mm	mm	mm	mm	-18°C	5°C	L	
FDQ-205	5/8	102	28	52	283	M10	4.2	7.0	1.8	A
FDQ-206	3/4	140	28	80	288	M10	5.3	9.2	3.5	A
FDQ-207	7/8	140	33	80	353	M10	9.5	16.2	4.4	A
FDQ-208	1-1/8	159	38	85	438	M10	15.5	26.7	7.2	A
FDQ-209	1-3/8	159	40	85	535	M12	25.3	42.9	8.9	A
FDQ-210	1-5/8	159	42	85	592	M12	37.6	64.0	9.9	A
FDQ-211	2-1/8	273	55	127	551	Φ11mm	74.5	126.3	22.6	B



Modelo A



Modelo B



# VERIFICATION OF CONFORMITY

Certificate No.: B-S2406C2384  
Client ID: CC6590



**Holder**.....: RGC REFRIGERATION PARTS C.A. CORP

**Address**.....: 2200 NW 72ND AVE #523223MIAMI, FL.33152

**Manufacturer**.....: Same As Holder

**Trade Mark**.....:



**Product**.....: Suction Line Accumulators

**Model No**.....: FDQE-207,FDQE-208,FDQE-209,FDQE-210,FDQE-211,FDQ-205,  
FDQ-206,FDQ-207,FDQ-208,FDQ-209,FDQ-210,FDQ-211

**Verification to**.....: European Directive(s): Pressure Equipment Directive 2014/68/EU  
EN 13445-1:2021

The test results apply only to the particular sample tested and to the specific tests carried out. Technical Report and documentation are at the Holder's disposal.

This certificate applies specifically to the sample investigated in our test reference number only. The CE markings as shown below can be affixed on the product after preparation of necessary technical documentation. Other relevant Directives have to be observed.

**Date of issue:** 2024-06-25

**Expiry date:** 2027-06-25



Certification Manager



**Beide (Shenzhen) Product Service Limited**

Address: 6F, Bldg E, Hourui 3rd Ind Zone, Xixiang, Bao'an Dist, Shenzhen, China  
E-mail: admin@szbeide.com Phone: +86 0755 27454498 www.szbeide.com

